

ОТЧЕТ  
ПАРАМЕТРАХ ТЕПЛОСНАБЖЕНИЯ  
за 22/09/21г. - 19/10/21г.

Абонент: ООО "УК" Комфортная среда  
 Адрес: Ул. Котлостроительная д. 25/1  
 Тепловычислитель ВКТ7 сет. N 1  
 Договорные расходы: \_\_\_\_\_ т.сут  
 М сет. воды = \_\_\_\_\_ т.сут  
 ТХВ = 5.00 град С

Заводской номер 00147074

ВВОД 1

СХЕМА ПОДКЛЮЧЕНИЯ 3

ФТ=0 ТЗ=0 КС=0Х76F8 по 2.7

Дата	t1	t2	dt	V1	M1	V2	M2	MГ	P1	P2	Q0	ВНР	ВОС	НС
	°C	°C	°C	М3	Т	М3	Т	Т	кг/см2	кг/см2	Гкал	ч	ч	ч
22/09/21	64.24	59.75	4.49	69.09	67.78	68.73	67.60	0.18	7.00	7.00	0.304	24	0	
23/09/21	60.71	56.68	4.03	55.51	54.55	55.37	54.53	0.02	7.00	7.00	0.216	24	0	
24/09/21	60.32	55.23	5.09	56.26	55.32	56.10	55.32	0.00	7.00	7.00	0.280	24	0	
25/09/21	58.14	53.82	4.32	68.89	67.81	68.59	67.63	0.18	7.00	7.00	0.303	24	0	
26/09/21	60.40	55.46	4.94	63.04	62.02	62.75	61.86	0.16	7.00	7.00	0.141	24	0	
27/09/21	58.34	53.73	4.61	31.81	31.30	31.97	31.54	-0.24	7.00	7.00	0.009	24	0	
28/09/21	34.09	32.99	1.10	5.43	5.40	5.13	5.10	0.30	7.00	7.00	0.000	24	0	
29/09/21	22.78	22.44	0.34	0.10	0.10	0.07	0.07	0.26	7.00	7.00	0.246	24	0	
30/09/21	53.32	47.29	6.03	41.50	40.90	41.62	41.16	-0.63	7.00	7.00	0.391	24	0	
01/10/21	56.69	55.00	5.67	69.97	68.79	70.39	69.42	-0.64	7.00	7.00	0.191	24	0	
02/10/21	60.99	52.49	4.20	46.13	45.45	46.47	45.89	-0.54	7.00	7.00	0.351	24	0	
03/10/21	58.57	55.50	5.49	65.00	63.88	65.37	64.42	-0.63	7.00	7.00	0.318	24	0	
04/10/21	58.57	53.46	5.11	65.60	62.71	64.18	65.20	-0.68	7.00	7.00	0.410	24	0	
05/10/21	60.66	54.67	5.99	65.64	64.52	66.75	63.89	0.67	7.00	7.00	0.361	24	0	
06/10/21	58.87	52.49	6.38	66.46	64.56	66.65	65.81	-0.39	7.00	7.00	0.315	24	0	
07/10/21	57.81	52.28	5.53	66.70	65.61	66.92	66.01	-0.42	7.00	7.00	0.400	24	0	
08/10/21	59.15	53.56	5.38	66.64	65.59	66.88	65.99	-0.37	7.00	7.00	0.375	24	0	
09/10/21	58.40	53.45	4.84	66.70	65.59	66.85	65.63	-0.33	7.00	7.00	0.318	24	0	
10/10/21	59.57	53.45	6.12	66.40	65.30	66.54	65.91	-0.24	7.00	7.00	0.414	24	0	
11/10/21	59.89	54.16	5.73	76.83	75.67	76.92	75.91	-0.22	7.00	7.00	1.419	24	0	
12/10/21	56.74	52.47	4.27	79.31	77.78	79.30	78.00	0.18	7.00	7.00	1.705	24	0	
13/10/21	65.70	60.37	5.33	134.64	132.03	133.68	131.85	0.94	7.00	7.00	2.764	24	0	
14/10/21	65.36	61.61	3.75	221.98	217.83	219.62	216.89	0.91	7.00	7.00	2.806	24	0	
15/10/21	64.03	51.61	12.42	239.67	235.20	237.34	229.13	1.33	7.00	7.00	2.865	24	0	
16/10/21	64.21	52.44	11.77	234.95	230.46	232.16	222.76	0.97	7.00	7.00	2.794	24	0	
17/10/21	64.97	52.78	12.19	227.27	222.73	224.71	221.76	0.97	7.00	7.00	2.794	24	0	
18/10/21	66.28	53.41	12.87	227.48	222.95	231.84	228.78	1.17	7.00	7.00	2.794	24	0	
19/10/21	65.51	53.34	12.17	234.48	229.95	231.84	228.78	1.17	7.00	7.00	2.794	24	0	
Итого:				2549.72	2504.25	2537.00	2502.98	1.27	7.00	7.00	21.729	672	0	
Средние:	58.44	52.12	6.32											
Итоговые параметры на 20/10/21г.			9 ч											
Дата	V1	M1	V2	M2	MГ	Q0	ВНР	ВОС						
	М3	Т	М3	Т	Т	Гкал	ч	ч						
20/10/21	110595.10	113927.39	112284.16	-1689.06	1305.032	21098	239							

20/10/21г. 9 ч 19.88.28  
 Период работы прибора после сброса  
 Представитель организации

